

### Overview

- The City of Sarasota (City) Water Treatment Plant (WTP) treats 12 million gallons per day (MGD) using ion exchange (IE) and reverse osmosis (RO) processes (Figure 1).
- Water is gathered from 51 surficial groundwater wells located 20 miles from the plant and several brackish water wells throughout the City's service area.
- The IE process and a raw water blend produces up to 7.5 MGD, while the RO process produces around 4.5 MGD, and then is blended altogether before final disinfection.
- Inter-stage boost recovers energy from the second stage concentrate to provide additional pressure to the second stage feed. This results in lower inputted feed pressure, therefore requiring less energy.




Figure 1: City's WTP Process Flow Diagram

### RO System

- 75% Recovery
- 1.5 MGD Capacity per Train
- Three 2-Stage (28x14) RO Trains (A,B,C)
- Six elements in each vessel
  - Stage 1: Hydranautics CPA3
  - Stage 2: Hydranautics ESPA2

### Objective

To evaluate the cost and performance impact of installing inter-stage turbines within the City of Sarasota's brackish water reverse osmosis desalination process

Table 1: Water Quality Ion Inputs

Feed Water Ion	Concentrations (mg/L)
Ca <sup>2+</sup>	279
Mg <sup>2+</sup>	135
Na <sup>+</sup>	294
Cl <sup>-</sup>	588
K <sup>+</sup>	6.60
Ba <sup>2+</sup>	16.2
Sr <sup>2+</sup>	21.9
HCO <sub>3</sub> <sup>-</sup>	136
SO <sub>4</sub> <sup>2-</sup>	858
SiO <sub>2</sub>	21.9

Table 2: Operations Inputs

Train	Feed pH	Feed Temperature (°F)	Feed Pressure (psi)	Permeate Flow (MGD)
A	7.13	77.0	219	1.48
B	7.13	77.0	218	1.47
C	7.13	77.0	217	1.46



Figure 2: Train C Side View




Figure 3: Hydranautics (San Diego, CA) Membrane Manufacturer Design Software



Figure 4: Train C Front Side View




Figure 5: Hydranautics Flow Diagram in Current Conditions  
1. Hexagonal numbers are pressure test points.

Table 3: Average Water Quality Outputs

Ion	Conc. (mg/L)
Ca <sup>2+</sup>	2.23
Mg <sup>2+</sup>	1.08
Na <sup>+</sup>	11.2
Cl <sup>-</sup>	15.7
K <sup>+</sup>	0.310
Ba <sup>2+</sup>	0.129
Sr <sup>2+</sup>	0.175
HCO <sub>3</sub> <sup>-</sup>	8.26
SO <sub>4</sub> <sup>2-</sup>	5.80
SiO <sub>2</sub>	0.529

Table 4: Average Train Operations Outputs

Stage 2 Feed Pressure (psi)	Value
Stage 2 Feed Pressure (psi)	177
Specific Energy (kWh/kgal)	2.61
Power Cost (\$/yr)	112,000




Figure 6: Hydranautics Flow Diagram with Booster Pump  
1. Hexagonal numbers are pressure test points.

Table 5: Average Water Quality Outputs

Ion	Conc. (mg/L)
Ca <sup>2+</sup>	1.94
Mg <sup>2+</sup>	0.940
Na <sup>+</sup>	9.79
Cl <sup>-</sup>	13.8
K <sup>+</sup>	0.271
Ba <sup>2+</sup>	0.113
Sr <sup>2+</sup>	0.153
HCO <sub>3</sub> <sup>-</sup>	7.22
SO <sub>4</sub> <sup>2-</sup>	5.06
SiO <sub>2</sub>	0.462

Table 6: Average Train Operations Outputs

Stage 2 Feed Pressure (psi)	Value
Stage 2 Feed Pressure (psi)	258
Specific Energy (kWh/kgal)	2.82
Power Cost (\$/yr)	121,000

### Results

Table 7: Economical-Energy Analysis of Inputting Inter-stage Turbines

Item	Results Trains A, B, and C
Permeate Flow (MGD)	1.47
Recovered Pressure (psi)	92.7
Δ Specific Energy (kWh/kgal)	0.205
Power Cost Savings (\$/yr)	8,700

Table 8: Cost Analysis of the Practicality of Inter-stage Turbines

Total Cost (\$)	Life Span (yr)	Power Saved (\$/yr)	Power Saved for Life Span (\$)	Overall Savings (\$)
234,000	5	26,100	131,000	-103,000
234,000	10	26,100	261,000	27,200

- Break point ≈ 8.96 years
- A 20-year life span will save \$288,000.

### Conclusions

- Investing in three inter-stage turbines, for a life expectancy of 20 years, will save the City \$14,400 annually.
- In a present-worth economic analysis, it will take approximately 9 years to recover the inter-stage turbine investment.
- Implementing inter-stage turbines would also balance the water flux, therefore reducing pressure loss, and increasing permeate water quality.

### Acknowledgements

This project was funded by the UCF's EXCEL Program with donations made by Duke Energy. I would like to express my sincere gratitude to the City of Sarasota Utilities Department, the UCF EXCEL Program Duke Energy, and the UCF Drinking Water Research Group, specifically Dr. Duranceau and Daniel Whalen, for their support and assistance in this research project.

